

**CERTIFICATE OF CONFORMANCE  
EUROPEAN COMMUNITY  
COUNCIL DIRECTIVE 2004/108/EC**

**Date of Issue:** April, 2012

**Issued By:** Retlif Testing Laboratories  
101 New Boston Road  
Goffstown, NH 03045

**Issued To:** Tecumseh Compression Company  
1136 Oak Valley Drive  
Ann Arbor, MI 48108

**Reference:** Retlif Report Number R-5581N-2

Retlif Testing Laboratories hereby acknowledges that compliance testing in accordance with the below listed standards was performed on a representative sample of the equipment listed below. Retlif Testing Laboratories further acknowledges that the test sample listed below was found to be in compliance with these standards. This certificate is hereby issued to the above named grantee and is valid only for the equipment identified below.

**Manufacturer:** Tecumseh Compression Company  
1136 Oak Valley Drive  
Ann Arbor, MI 48108

**Equipment Tested:** 48 VDC BLDC Hermetic Compressor and Controller

**Part Numbers:** Cascade0003 & 03OF0137

**Model Numbers:** Cascade17-0306Y3 & 48VDC Cascade Controller

**Serial Numbers:** 64G28111G069398B & C1411000001

**Brand Name:** Tecumseh

**Product Type:** Telecommunication Network Equipment

**Note(s):** 1) See attached report R-5581N-2 for details and/or conditions pertaining to this certificate.  
2) Conforms to the emissions requirements of EN 300 386 v1.5.1:2010:  
EN 55022: 2006 w/A1:2007 Conducted Emissions  
EN 55022: 2006 w/A1:2007 Radiated Emissions  
3) Conforms to the immunity requirements of EN 300 386 v1.5.1:2010:  
EN 61000-4-3: 2006 Radiated Immunity  
EN 61000-4-4: 2004 EFT/Burst, Power and I/O Leads  
EN 61000-4-6: 2009 Conducted Immunity, Power and I/O Leads